

**Customer :**

**Date:** 18.may.2020

**Certificate No:** FRO-407C/120513

**Container:** F407c 25ibs/11.3kg

**Customer PO:** Frogen 407C

**Page No:** 1 of 1

**FROGEN® 407C**  
**Refrigeration Grade**  
Meets ARI 700-95 Specification For R 407C.

**Certificate of Analysis**

Test	Specification	Result	Method
F32	21.0 to 25.0	24.41%	AAP-QCL-033
F125	23.0 to 27.0	25.04%	AAP-QCL-033
F134A	50.0 TO 54.0	50.55%	AAP-QCL-033
Purity	99.7min	100.00%	AAP-QCL-033
Acidity	0.0015 max	Not detected mg KOH/g	AAP-QCL-070
Moisture	0.0010 max	0.00%	AAP-QCL-090
Halides	1 max	Not detected ppm	AAP-QCL-063
Non condensables	1.5 max.	0.36%	AAP-QCL-031
Residue	0.0010 max	0%	AAP-QCL-051

  
 Quality Control Dept.