



KIA SARMA IRANIAN

www.kiasarma.com

Honeywell

P.O. Box 2830
Baton Rouge, La. 70821
Phone# (225) 383-5222
Fax# (225) 346-3689

Genetron® 407c Standard Grade

Certificate of Analysis

Test	Specification	Result	Units	Method
G32	21.0 to 25.0	24.6	%	PRC-QCL-033
G125	23.0 to 27.0	25.2	%	PRC-QCL-033
G134A	50.0 to 54.0	50.2	%	PRC-QCL-033
Total Chlorinated Organics	0.2500 max.	<0.2500	%	PRC-QCL-033
Unsaturated Compounds	0.0040 max.	<0.0040	%	PRC-QCL-033
Fluorinated Unsat Comp	0.0020 max.	<0.0020	%	PRC-QCL-033
Total organic impurities	0.2500 max.	<0.2500	%	PRC-QCL-033
Acidity	0.0015 max.	Not Detected	mg KOH/g	PRC-QCL-070
Moisture	0.0010 max.	0.0004	%	PRC-QCL-090
Halides	1 max.	Not Detected	ppm	PRC-QCL-070
Non condensables	1.5 max.	0.8	%	PRC-QCL-033
Residue	0.0010 max.	0.0002	%	PRC-QCL-051
Odor	PASS	PASS	Pass/Fail	PRC-QCL-063
Appearance	PASS	PASS	Pass/Fail	PRC-QCL-063

Comments

Honeywell Fluorine Products Europe
Laarderhoogtweg 12
1101 EA Amsterdam
Netherlands

Generated By: Quality Control

Approved By:

Dan Niwa
Quality Systems Leader

21 AUG 2015